



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Whitman Elementary School

827 Whitman School Drive
Turnersville, NJ 08012

Results of Lead Analysis

Date & Time Sampled: 03/17/2017 05:00 - 06:56

Date & Time Analyzed: 03/28/2017 18:39 - 19:31

Date & Time Analyzed: 03/29/2017 10:13 - 15:15

Sample Location	First Draw	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
WHIT-BLB-F1	<2.00	15.5
WHIT-BLB-F2	<2.00	15.5
WHIT-BLB-F3	<2.00	15.5
WHIT-BLB-F4	<2.00	15.5
WHIT-FT2	<2.00	15.5
WHIT-S1	<2.00	15.5
WHIT-S3	<2.00	15.5
WHIT-S4	<2.00	15.5
WHIT-S5	<2.00	15.5
WHIT-S6	<2.00	15.5
WHIT-IM	<2.00	15.5
WHIT-BLB-F5	<2.00	15.5
WHIT-BLB-F6	<2.00	15.5
WHIT-BLB-F7	<2.00	15.5
WHIT-BLB-F9	<2.00	15.5
WHIT-BLB-F8	<2.00	15.5
WHIT-BLB-F10	2.66	15.5
WHIT-BLB-F11	<2.00	15.5
WHIT-BLB-F13	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Whitman Elementary School

827 Whitman School Drive
Turnersville, NJ 08012

Results of Lead Analysis


Date & Time Sampled: 03/17/2017 05:00 - 06:56

Date & Time Analyzed: 03/28/2017 18:39 - 19:31

Date & Time Analyzed: 03/29/2017 10:13 - 15:15

Sample Location	First Draw	Action Level
WHIT-BLB-F14	<2.00	15.5
WHIT-BLB-F12	<2.00	15.5
WHIT-BLB-F15	<2.00	15.5
WHIT-BLB-F16	2.24	15.5
WHIT-FT3	2.59	15.5
WHIT-BLB-FT17	<2.00	15.5
WHIT-BLB-FT18	<2.00	15.5
WHIT-BLB-FT19	<2.00	15.5
WHIT-BLB-FT20	<2.00	15.5
WHIT-BLB-FT22	<2.00	15.5
WHIT-BLB-FT21	2.05	15.5
WHIT-BLB-FT23	<2.00	15.5
WHIT-BLB-FT24	<2.00	15.5
WHIT-BLB-R2	<2.00	15.5
WHIT-BLB-R1	<2.00	15.5
WHIT-BLB-R3	<2.00	15.5
WHIT-BLB-R4	<2.00	15.5
WHIT-BLB-R5	<2.00	15.5
WHIT-FT8	17.7	15.5
WHIT-FT9	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Whitman Elementary School

827 Whitman School Drive
Turnersville, NJ 08012

Results of Lead Analysis

Date & Time Sampled: 03/17/2017 05:00 - 06:56

Date & Time Analyzed: 03/28/2017 18:39 - 19:31

Date & Time Analyzed: 03/29/2017 10:13 - 15:15


Sample Location	First Draw	Action Level
WHIT-FT7	<2.00	15.5
WHIT-FT6	<2.00	15.5
WHIT-BLB-R6	<2.00	15.5
WHIT-BLB-R7	<2.00	15.5
WHIT-BLB-R8	<2.00	15.5
WHIT-BLB-R10	<2.00	15.5
WHIT-FT5	<2.00	15.5
WHIT-FT4	<2.00	15.5
WHIT-BLB-R9	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director


Date