



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Bob Kulp
Northeastern Flooring
447 Commerce lane
Suite A
West Berlin, NJ 08091

3/10/2017

Phone: (856) 809-0100
Fax: (856) 809-0606

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/3/2017. The results are tabulated on the attached data pages for the following client designated project:

Bunker Hill School

The reference number for these samples is EMSL Order #011701684. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701684

CustomerID: NEFR42

CustomerPO:

ProjectID:

Attn: **Bob Kulp**
Northeastern Flooring
447 Commerce lane
Suite A
West Berlin, NJ 08091

Phone: (856) 809-0100
 Fax: (856) 809-0606
 Received: 03/03/17 2:00 PM

Project: **Bunker Hill School****Analytical Results****Client Sample Description** Urethane #1**Collected:** 2/17/2017 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
TCLP 1311/6010C	Arsenic	ND	0.10	mg/L	3/7/2017	LY	3/8/2017	JS
TCLP 1311/6010C	Barium	ND	0.50	mg/L	3/7/2017	LY	3/8/2017	JS
TCLP 1311/6010C	Cadmium	ND	0.10	mg/L	3/7/2017	LY	3/8/2017	JS
TCLP 1311/6010C	Chromium	ND	0.10	mg/L	3/7/2017	LY	3/8/2017	JS
TCLP 1311/6010C	Lead	ND	0.10	mg/L	3/7/2017	LY	3/8/2017	JS
TCLP 1311/6010C	Selenium	ND	0.10	mg/L	3/7/2017	LY	3/8/2017	JS
TCLP 1311/6010C	Silver	ND	0.10	mg/L	3/7/2017	LY	3/8/2017	JS
TCLP 1311/7470A	Mercury	1.8	0.20	mg/L	3/9/2017	CM	3/9/2017	CM

Exceeded the TCLP regulatory limit of 0.20 mg/l

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)