



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Chestnut Ridge Middle School

641 Hurffville/Crosskeys Road
Sewell, NJ 08080

Results of Lead Analysis

Date & Time Sampled: 05/24/2017 05:55 - 06:11

Date & Time Analyzed: 05/31/2017 20:21 - 21:41


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
CRMS-ST1	18.7	15.5
CRMS-ST2	14.2	15.5
CRMS-S14	37.4	15.5
CRMS-S10	<2.00	15.5
CRMS-S15	16.9	15.5
CRMS-ST1 (Flushed)	<2.00	15.5
CRMS-ST2 (Flushed)	<2.00	15.5
CRMS-S14 (Flushed)	<2.00	15.5
CRMS-S10 (Flushed)	<2.00	15.5
CRMS-S15 (Flushed)	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director


Date