



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #08006

Birches Elementary School

416 Westminster Boulevard
Turnersville, NJ 08012

Results of Lead Analysis

Date & Time Sampled: 03/16/2017 05:02 - 06:23

Date & Time Analyzed: 03/28/2017 13:13 - 18:33

Sample Location	First Draw	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
Birches-BLB-F1	4.88	15.5
Birches-BLB-F2	6.38	15.5
Birches-BLB-F3	71.4	15.5
Birches-BLB-F4	4.36	15.5
Birches-BLB-F5	2.41	15.5
Birches-BLB-F6	2.93	15.5
Birches-BLB-F7	3.80	15.5
Birches-BLB-F8	2.11	15.5
Birches-FT1	5.17	15.5
Birches-FT2	<2.00	15.5
Birches-S4	3.35	15.5
Birches-S5	2.98	15.5
Birches-S2	<2.00	15.5
Birches-IM1	<2.00	15.5
Birches-S1	4.22	15.5
Birches-BLB-F9	2.26	15.5
Birches-BLB-F10	<2.00	15.5
Birches-BLB-F12	<2.00	15.5
Birches-BLB-F11	4.20	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Birches Elementary School

416 Westminster Boulevard
Turnersville, NJ 08012

Results of Lead Analysis

Date & Time Sampled: 03/16/2017 05:02 - 06:23

Date & Time Analyzed: 03/28/2017 13:13 - 18:33

Sample Location	First Draw	Action Level
Birches-BLB-F14	21.2	15.5
Birches-BLB-F13	11.0	15.5
Birches-BLB-F16	3.86	15.5
Birches-BLB-F17	10.7	15.5
Birches-BLB-F15	<2.00	15.5
Birches-BLB-F18	183	15.5
Birches-FT3	3.55	15.5
Birches-BLB-F19	<2.00	15.5
Birches-BLB-F20	23.7	15.5
Birches-BLB-F21	15.4	15.5
Birches-BLB-F22	<2.00	15.5
Birches-BLB-F23	15.0	15.5
Birches-BLB-F25	3.90	15.5
Birches-BLB-F24	6.89	15.5
Birches-BLB-F26	<2.00	15.5
Birches-BLB-F27	3.79	15.5
Birches-R1	<2.00	15.5
Birches-S7	<2.00	15.5
Birches-FT8	<2.00	15.5
Birches-FT9	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Birches Elementary School

416 Westminster Boulevard
Turnersville, NJ 08012

Results of Lead Analysis

Date & Time Sampled: 03/16/2017 05:02 - 06:23


Date & Time Analyzed: 03/28/2017 13:13 - 18:33

Sample Location	First Draw	Action Level
Birches-FT6	<2.00	15.5
Birches-FT7	376	15.5
Birches-BLB-R2	<2.00	15.5
Birches-BLB-R3	<2.00	15.5
Birches-BLB-R5	<2.00	15.5
Birches-FT4	8.24	15.5
Birches-FT5	20.3	15.5
Birches-BLB-R4	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.
Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director


Date