

**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Bells Elementary School

227 Greentree Road
Turnersville, NJ 08012

Results of Lead Analysis


Date & Time Sampled: 03/15/2017 04:58 - 06:15

Date & Time Analyzed: 03/24/2017 15:39 - 20:07

Date & Time Analyzed: 03/27/2017 16:53 - 18:59

Sample Location	First Draw	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
BELLS-BLB-F2	<2.00	15.5
BELLS-BLB-F1	<2.00	15.5
BELLS-BLB-F3	<2.00	15.5
BELLS-BLB-F4	<2.00	15.5
BELLS-FT1	<2.00	15.5
BELLS-FT2	<2.00	15.5
BELLS-S1	<2.00	15.5
BELLS-IM2	<2.00	15.5
BELLS-S3	<2.00	15.5
BELLS-S5	<2.00	15.5
BELLS-BLB-F5	<2.00	15.5
BELLS-IM1	<2.00	15.5
BELLS-BLB-F7	<2.00	15.5
BELLS-BLB-F6	<2.00	15.5
BELLS-BLB-F9	<2.00	15.5
BELLS-BLB-F8	<2.00	15.5
BELLS-BLB-F10	<2.00	15.5
BELLS-BLB-F12	<2.00	15.5
BELLS-BLB-F11	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Bells Elementary School

227 Greentree Road
Turnersville, NJ 08012

Results of Lead Analysis

Date & Time Sampled: 03/15/2017 04:58 - 06:15

Date & Time Analyzed: 03/24/2017 15:39 - 20:07

Date & Time Analyzed: 03/27/2017 16:53 - 18:59

Sample Location	First Draw	Action Level
BELLS-BLB-F14	<2.00	15.5
BELLS-BLB-F13	<2.00	15.5
BELLS-BLB-F15	<2.00	15.5
BELLS-FT3	<2.00	15.5
BELLS-BLB-F16	287	15.5
BELLS-BLB-F17	2.76	15.5
BELLS-BLB-F19	<2.00	15.5
BELLS-BLB-F18	<2.00	15.5
BELLS-BLB-F20	<2.00	15.5
BELLS-BLB-F23	<2.00	15.5
BELLS-BLB-F21	<2.00	15.5
BELLS-BLB-F22	<2.00	15.5
BELLS-BLB-F24	<2.00	15.5
BELLS-BLB-R2	<2.00	15.5
BELLS-BLB-R1	<2.00	15.5
BELLS-FT8	<2.00	15.5
BELLS-FT9	<2.00	15.5
BELLS-FT6	<2.00	15.5
BELLS-FT7	<2.00	15.5
BELLS-BLB-R3	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Bells Elementary School

227 Greentree Road
Turnersville, NJ 08012

Results of Lead Analysis

Date & Time Sampled: 03/15/2017 04:58 - 06:15

Date & Time Analyzed: 03/24/2017 15:39 - 20:07

Date & Time Analyzed: 03/27/2017 16:53 - 18:59


Sample Location	First Draw	Action Level
BELLS-BLB-R4	<2.00	15.5
BELLS-BLB-R5	<2.00	15.5
BELLS-BLB-R6	15.9	15.5
BELLS-FT4	<2.00	15.5
BELLS-FT5	<2.00	15.5
BELLS-BLB-R8	<2.00	15.5
BELLS-BLB-R10	<2.00	15.5
BELLS-BLB-R9	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director


Date