



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Bunker Hill Middle School

372 Pitman Downer Road
Sewell, NJ 08080

Results of Lead Analysis

Date & Time Sampled: 03/18/2017 09:15 - 10:24

Date & Time Analyzed: 03/30/2017 13:54 - 14:18

Sample Location	First Draw	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
BHMS-FT13	<2.00	15.5
BHMS-FT14	<2.00	15.5
BHMS-FT17	<2.00	15.5
BHMS-FT18	<2.00	15.5
BHMS-FT1	<2.00	15.5
BHMS-FT2	<2.00	15.5
BHMS-FT3	<2.00	15.5
BHMS-FT4	<2.00	15.5
BHMS-FT5	<2.00	15.5
BHMS-FT6	<2.00	15.5
BHMS-S6	736	15.5
BHMS-S7	171	15.5
BHMS-S9	63.0	15.5
BHMS-S10	6.51	15.5
BHMS-S11	<2.00	15.5
BHMS-S8	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Bunker Hill Middle School

372 Pitman Downer Road
Sewell, NJ 08080

Results of Lead Analysis

Date & Time Sampled: 03/18/2017 09:15 - 10:24

Date & Time Analyzed: 03/30/2017 13:54 - 14:18

Sample Location	First Draw	Action Level
BHMS-FT7	<2.00	15.5
BHMS-FT8	<2.00	15.5
BHMS-S13	<2.00	15.5
BHMS-FT11	<2.00	15.5
BHMS-FT12	<2.00	15.5
BHMS-S5	3.11	15.5
BHMS-ST1	66.8	15.5
BHMS-ST2	47.4	15.5
BHMS-S4	<2.00	15.5
BHMS-S2	<2.00	15.5
BHMS-S3	<2.00	15.5
BHMS-IM1	<2.00	15.5
BHMS-S1	<2.00	15.5
BHMS-S15	2.59	15.5
BHMS-FT9	<2.00	15.5
BHMS-FT10	<2.00	15.5
BHMS-S14	<2.00	15.5
BHMS-S12	<2.00	15.5
BHMS-FT15	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Bunker Hill Middle School

372 Pitman Downer Road
Sewell, NJ 08080

Results of Lead Analysis

Date & Time Sampled: 03/18/2017 09:15 - 10:24


Date & Time Analyzed: 03/30/2017 13:54 - 14:18

Sample Location	First Draw	Action Level
BHMS-FT16	<2.00	15.5
BHMS-S20	125	15.5
BHMS-S19	2.58	15.5
BHMS-S17	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.
Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

4/3/17
Date