

**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Chestnut Ridge Middle School

641 Hurffville/Crosskeys Road
Sewell, NJ 08080


Results of Lead Analysis

Date & Time Sampled: 03/18/2017 06:17 - 07:23

Date & Time Analyzed: 03/29/2017 10:46 - 16:30

Sample Location	First Draw	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
CRMS-FT1	<2.00	15.5
CRMS-S1	<2.00	15.5
CRMS-S2	<2.00	15.5
CRMS-S3	<2.00	15.5
CRMS-S5	<2.00	15.5
CRMS-S6	<2.00	15.5
CRMS-S7	<2.00	15.5
CRMS-ST1	70.0	15.5
CRMS-ST2	34.1	15.5
CRMS-S8	<2.00	15.5
CRMS-FT6	<2.00	15.5
CRMS-FT2	<2.00	15.5
CRMS-FT3	<2.00	15.5
CRMS-FT5	<2.00	15.5
CRMS-FT9	<2.00	15.5
CRMS-FT10	<2.00	15.5
CRMS-FT11	<2.00	15.5
CRMS-FT12	3.10	15.5
CRMS-FT14	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Chestnut Ridge Middle School

641 Hurffville/Crosskeys Road
Sewell, NJ 08080


Results of Lead Analysis

Date & Time Sampled: 03/18/2017 06:17 - 07:23

Date & Time Analyzed: 03/29/2017 10:46 - 16:30

Sample Location	First Draw	Action Level
CRMS-FT7	<2.00	15.5
CRMS-FT15	<2.00	15.5
CRMS-FT22	<2.00	15.5
CRMS-FT23	<2.00	15.5
CRMS-S13	4.04	15.5
CRMS-S12	<2.00	15.5
CRMS-S11	<2.00	15.5
CRMS-IM	<2.00	15.5
CRMS-S9	<2.00	15.5
CRMS-S10	50.2	15.5
CRMS-FT18	<2.00	15.5
CRMS-FT19	<2.00	15.5
CRMS-FT20	<2.00	15.5
CRMS-FT31	<2.00	15.5
CRMS-FT33	<2.00	15.5
CRMS-S17	4.34	15.5
CRMS-FT26	<2.00	15.5
CRMS-FT27	<2.00	15.5
CRMS-FT28	<2.00	15.5
CRMS-FT29	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Chestnut Ridge Middle School

641 Hurffville/Crosskeys Road
Sewell, NJ 08080

Results of Lead Analysis

Date & Time Sampled: 03/18/2017 06:17 - 07:23

Date & Time Analyzed: 03/29/2017 10:46 - 16:30

Sample Location	First Draw	Action Level
CRMS-S14	21.0	15.5
CRMS-S15	19.8	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.
Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

Mark J. Riether, Laboratory Director

4/3/17

Date